



Product Service

Attestation of Conformity

No. N8A 17 06 99389 001

Holder of Certificate: **Shanghai Saintsun Electrical Technologies Co., Ltd**

No.56 Hexi Street, Xiaokunshan Town,
Songjiang District,
201616 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Product: **Switches**
Switch-Disconnecter

Model(s): **AW series**
(more details see Annex A)

Parameters:

Rated voltage:	DC600V(2P), DC1000V(2P, 3P)
Rated current:	16A, 20A, 25A, 32A, 40A
Utilization of category:	DC-21B
Rated short-time withstand current Icw:	16A:480A/1s; 20A:600A/1s; 25A:750A/1s; 32A:960A/1s; 40A:1200A/1s
Rated short-time making capacity Icm:	1400A

Tested according to: EN 60947-3:2009/A2:2015
EN 60947-1:2007/A2:2014

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 704101753201-00

Date, 2017-06-28

(Yi Zhu)



After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.