

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Low voltage switchgear and controlgear; Switch-disconnector
Name and address of the applicant	Shanghai Saintsun Electrical Technologies. Co., Ltd., No. 56 Hexi Street, Xiaokunshan Town, Songjiang District Shanghai, CHINA
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	Ue= DC600V(2P), DC1000V(2P, 3P) Ie= 16, 20, 25, 32, 40A Icw= 16A: 480A/1s; 20A: 600A/1s; 25A: 750A/1s; 40A: 1200A/1
Trademark (if any)	STSUN
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	AW**-****-**-**
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2008+A1+A2
As shown in the Test Report Ref. No. which forms part of this Certificate	170302431SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 18 May 2017

Signature: 

Bo Berglöv